



EFFECTIS ERA AVRASYA TEST VE BELGELENDİRME A.Ş.
Dilovası OSB 5. Kısım Fırat Caddesi No:18
41455 Dilovası KOCAELİ
www.effectis.com

TEST CERTIFICATE

Certificate Nr: EEA-1800-0057

The related reaction to fire test was carried out at Efectis Era Avrasya Test Laboratories on 30th July 2018 in accordance with EN 13501-1:2007+A1:2009 standard for the product as described below:

“ ROCKWOOL FILLED WALL PANEL 50 mm ”

Fire behaviour	Smoke production	Flaming droplets
A2	- s 1 ,	d 0

Placed on the market by

EST PANEL SİSTEMLERİ SAN. VE TİC. LTD. ŞTİ.
VELİMEŞE OSB 244. SOK. NO: 3 ERGENE, TEKİRDAĞ, TURKEY

And Produced In the Factory

EST PANEL SİSTEMLERİ SAN. VE TİC. LTD. ŞTİ.
VELİMEŞE OSB 244. SOK. NO: 3 ERGENE, TEKİRDAĞ, TURKEY

This test certificate is a declaration of the test results and does not represent any type approval or certification of the product. All details related to product specifications and field of application are described in the classification report Nr. **ERA-18-132**.

This certificate is initially valid until 10th August 2019 providing that no significant modifications are made in technical specification of the specimen and related test and classification standards.

Ali BAYRAKTAR
Laboratory Manager
10.08.2018

